

Changes Effective July 1, 2014

Permit Requirements for the electrical installation and maintenance of signs

Field wired signs or equivalent

Electrical contractors are required to submit an electrical permit for the installation of high, low or extra low voltage field wiring of a sign. This includes but not limited to the electrical maintenance and/or repair of field wired signs and their components or the conversion of the lighting source, wiring method or power supply.

Self-contained signs or equivalent

Electrical contractors are required to submit an electrical permit for the electrical maintenance and/or repair of self-contained signs performed in the field. . This includes but not limited to the conversion of the lighting source, wiring method or power supply.

Permit fees

Permit fees shall include all labour and material to install the sign including the retail sign value as required by the Electrical Fee Schedule prescribed by SaskPower Electrical Inspection.

Certification of signs or equivalent

All individual electrically lighted signs or equivalent shall be certified for use in Saskatchewan. When a sign or equivalent has been modified from the original certification it shall than be re-certified.

